



# DVGW type examination certificate

## DVGW-Baumusterprüfzertifikat

**DG-4394BU0121**  
Registration Number  
Registriernummer

<b>Field of Application</b> <i>Anwendungsbereich</i>	products of gas supply <i>Produkte der Gasversorgung</i>
<b>Owner of Certificate</b> <i>Zertifikatinhaber</i>	Andronaco S.A.S. 30, rue Jean Jaurès, F-42240 Unieux
<b>Distributor</b> <i>Vertreiber</i>	Andronaco S.A.S. 30, rue Jean Jaurès, F-42240 Unieux
<b>Product Category</b> <i>Produktart</i>	Gas fittings: HDPE shut-off valve, manufacturing group 1 (4394)
<b>Product description</b> <i>Produktbezeichnung</i>	straight pattern shut-off valve made of PE 100 with spherical body
<b>Model</b> <i>Modell</i>	Polyvalve
<b>Test reports</b> <i>Prüfberichte</i>	Laboratory control test: 21-00768-KP07-17 from 29.04.2024 (EBI) Type testing: 08/080/4394/994 from 20.02.2009 (EBI)
<b>Test basis</b> <i>Prüfgrundlagen</i>	DVGW VP 302 (01.06.2006)

**Date of Expiry / File No.** 20.02.2026 / 24-0119-GNV  
*Ablaufdatum / Aktenzeichen*

70028-04-A-DE

09.05.2025 Cz A-1/2

Date, Issued by, Sheet, Head of Certification Body  
*Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle*

*JA. 20. 21*



DVGW CERT GmbH  
Josef-Wirmer-Str. 1-3  
53123 Bonn  
Tel. +49 228 9188-888  
info@dvgw-cert.com  
www.dvgw-cert.com

<b>Gas Category</b> <i>Gasart</i>	<b>Remarks</b> <i>Bemerkungen</i>
Fuel gases according to G 260	

<b>Type</b> <i>Typ</i>	<b>Technical Data</b> <i>Technische Daten</i>	<b>Remarks</b> <i>Bemerkungen</i>
Polyvalve	Nominal diameter: 50 mm	
Polyvalve	Nominal diameter: 63 mm	
Polyvalve	Nominal diameter: 90 mm	
Polyvalve	Nominal diameter: 110 mm	
Polyvalve	Nominal diameter: 125 mm	
Polyvalve	Nominal diameter: 160 mm	
Polyvalve	Nominal diameter: 180 mm	
Polyvalve	Nominal diameter: 200 mm	
Polyvalve	Nominal diameter: 225 mm	

**Hints of Utilization / Remarks**  
*Verwendungshinweise / Bemerkungen*

connection: at both sides pipe made of PE 100 (SDR 11)  
 ambient temperature range: -20...+60 °C  
 max. operation pressure: 10 bar