

Approval Number 240855041  
Test Report: PB2024001766, PB2024001865, PB2024001866  
&PB2024001868



Water Regulations Approval Scheme Ltd.  
Unit 13,  
Willow Road,  
Pen y Fan Industrial Estate,  
Crumlin,  
Gwent,  
NP11 4EG

1<sup>st</sup> October 2024

Arkema France  
CERDATO,  
Route du Launay,  
27470 Serquigny,  
France

**WATER REGULATIONS APPROVAL SCHEME LTD. (WRAS)**  
**MATERIAL APPROVAL**

The material referred to in this letter is suitable for contact with wholesome water for domestic purposes having met the requirements of BS6920-1:2000 and/or 2014 'Suitability of non-metallic products for use in contact with water intended for human consumption with regard to their effect on the quality of the water'.

The reference relates solely to its effect on the quality of the water with which it may come into contact and does not signify the approval of its mechanical or physical properties for any use.

**COATINGS, PAINTS & LININGS- FACTORY APPLIED PIPE & FITTINGS COATINGS.**

**5030**

'PRIMGREEN® ENDURANCE & Primgreen LAT 12035' primers for use with 'RILSAN® PA11 T BLUE 7444 MAC (16293), PA11 T GREY 5161 MAC (17203), PA11 T WHITE 1488 AC (17219) & PA11 T BLACK 7450 AC (17185)' coatings.

Factory applied primers and powder coatings. The piece to be coated is to be pre-heated to 330°C for 10 minutes, the primer and coating applied in accordance with user instructions 'Dircom - 4418E/05.2015/20' and then cured for 10 minutes@330°C.

For use with water up to 60°C.

This material is only approved for the curing conditions that appear on the approval. If the cure conditions are varied from those specified on the approval then the material is not covered by the scope of the approval.

**APPROVAL NUMBER: 240855041**  
**APPROVAL HOLDER: ARKEMA FRANCE**

The Scheme reserves the right to review approval.  
Approval 240855041 is valid between August 2024 and August 2029

An entry, as above, will accordingly be included in the Water Fittings Directory on-line under the section headed, "Materials which have passed full tests of effect on water quality".

The Directory may be found at: [www.wrasapprovals.co.uk/approvals-directory/](http://www.wrasapprovals.co.uk/approvals-directory/)

Yours Faithfully

**Ian Hughes**  
**WRAS Approvals Manager**