

Approval Number 2212559  
Test Report: J-00437608 & J-00437609



Water Regulations Approval Scheme Ltd.  
Unit 13,  
Willow Road,  
Pen y Fan Industrial Estate,  
Crumlin,  
Gwent,  
NP11 4EG

24<sup>th</sup> January 2023

Polymer-Technik Elbe GmbH  
Heuweg 5,  
06886 Lutherstadt Wittenberg,  
Germany

**WATER REGULATIONS APPROVAL SCHEME LTD. (WRAS)  
MATERIAL APPROVAL**

The material referred to in this letter is suitable for contact with wholesome water for domestic purposes having met the requirements of BS6920-1:2000 and/or 2014 'Suitability of non-metallic products for use in contact with water intended for human consumption with regard to their effect on the quality of the water'.

The reference relates solely to its effect on the quality of the water with which it may come into contact and does not signify the approval of its mechanical or physical properties for any use.

**RUBBERS- ETHYLENE PROPYLENE DIENE MONOMER (EPDM) - MATERIAL ONLY.**

**5365**

'TWK7534, TWK5810, TWK5811, TWK5812, TWK5813, TWK5814, TWK5815'. Black coloured, injection moulded EPDM materials. Shore hardness between 55A & 85A. Tested in-radius size 1.0mm. For use with water up to 85°C.

**APPROVAL NUMBER: 2212559**

**APPROVAL HOLDER: POLYMER-TECHNIK ELBE GMBH**

The Scheme reserves the right to review approval.  
Approval 2212559 is valid between December 2022 and December 2027

An entry, as above, will accordingly be included in the Water Fittings Directory on-line under the section headed, "Materials which have passed full tests of effect on water quality".

The Directory may be found at: [www.wrasapprovals.co.uk/approvals-directory/](http://www.wrasapprovals.co.uk/approvals-directory/)

Yours Faithfully

A handwritten signature in blue ink, appearing to read 'Ian Hughes', is written over a horizontal line.

**Ian Hughes**  
**WRAS Approvals Manager**