



Österreichische Vereinigung für das Gas- und Wasserfach
A-1010 Wien, Schuberttring 14
Telefon: +43 / 1 / 513 15 88-0* / Telefax: +43 / 1 / 513 15 88-25
E-Mail: office@ovgw.at / Internet: www.ovgw.at
Accredited by the Federal Ministry
for Labour and Economy



ÖVGW Certificate

of the conferment of the right to use
the ÖVGW Quality Mark for Water

Registration number

W 1.565

Period of validity

until the end of October 2026

Owner ♦ Distribution in Austria

E. Hawle Armaturenwerke GmbH
Wagrainerstraße 13
4840 Vöcklabruck

Manufacturer

E. Hawle Armaturenwerke GmbH / AT

Type of test

Supplementary test

Reason for supplement

- Type 7974: Extension to include DN 125, 350, 400, 450, 500 and 600, PFA 16 bar (deletion of PFA 10 bar)
- Type 7994: Extension to include DN 125, 350, 400, 450, 500 and 600, PFA 16 bar (deletion of PFA 10 bar)
- Type 7980: Extension to include DN 125, PFA 16 bar

Test report

TGM – VA HL 9263 dated 26 July 2024

Quality standards / Testing directives

- QS-W 503 version January 2021 in combination with ÖNORM Standards EN 14525 and EN 14901
- QS-W 100 version November 2022
- QS-W 200 version May 2020

Product

Wide-tolerance couplings and flange adapters

Hawle-SYNOFLEX™

for the drinking-water supply system,

flexible and traction-secured fittings made of ductile cast iron with epoxy resin powder coating for connecting pipes made of polyethylene (PE), polyvinylchloride (PVC), steel, cast and asbestos cement (not secured against traction)

Type: 7974 Connector and reducing connector (sleeve to sleeve) with the dimensions: DN 40, 50, 65, 80, 100, 125, 150, 200, 225, 250, 300, 350, 400, 450, 500 and 600; PFA 16 bar

Type: 7994 Flange and reducing flange (flange to sleeve) with the dimensions: DN 50, 65, 80, 100, 125, 150, 200, 225, 250, 300, 350, 400, 450 500 and 600; PFA 16 bar

Type: 7980 End cap with or with/without 2" outlet (sleeve) with the dimensions: DN 50, 65, 80, 100, 125, 150, 200, 225, 250, 300; PFA 16 bar
DN 350, 400; PFA 10 bar

Type: 7981 Duckfoot bend (flange to sleeve) with the dimensions:
DN 80, 100; PFA 16 bar

The conferment is based on the General Terms and Conditions GW 30 ÖVGW Quality Mark for Gas & Water Products
"Conditions for the award of the ÖVGW Quality Mark for gas and water supply products."

Vienna, 19 August 2024

Dipl.-Ing. (FH) Alexander Schwanzer
Head of the ÖVGW Certification Office