



Österreichische Vereinigung für das Gas- und Wasserfach
A-1010 Wien, Schuberttring 14
Telefon: +43 / 1 / 513 15 88-0* / Telefax: +43 / 1 / 513 15 88-25
E-Mail: office@ovgw.at / Internet: www.ovgw.at
Accredited by the Federal Ministry
for Labour and Economy



ÖVGW Certificate

of the conferment of the right to use
the ÖVGW Quality Mark for Water

Registration number

W 1.166

Period of validity

until the end of April 2027

Owner ♦ Distribution in Austria

E. Hawle Armaturenwerke GmbH
Wagrainerstraße 13
4840 Vöcklabruck

Manufacturer

E. Hawle Armaturenwerke GmbH / AT

Type of test

Renewal and supplementary test

Product

Combi – III

Flange T-piece with shut-off valve
(soft-sealing wedge gate valve)
with 2 or 3 shut-offs

for drinking water supply
with cold water, PN16

Type: 4450 E3
DN 80, 100, 125, 150, 200
without vertical connection

4460 E3
DN 80, 150, 200
with vertical connection

Reason for supplement

Change of rubber compound from T8165 to
T5821

with the following registration features:
• for underground and shaft installations
• manually or motor-operated

Test report

TGM – VA HL 9226 dated 30 August 2024

Quality standards / Testing directives

- QS-W 501/1 (version December 2014)
(including version November 2023) in
combination with ÖNORM Standards
EN 1074-1:2000 and EN 1074-2:2004

The conferment is based on the General Terms and Conditions GW 30 ÖVGW Quality Mark for Gas & Water Products
"Conditions for the award of the ÖVGW Quality Mark for gas and water supply products."

Vienna, 9 October 2024


Dipl.-Ing. (FH) Alexander Schwanzer
Head of the ÖVGW Certification Office